

SKIN TEMPERATURES AND THERMAL JUDGMENTS IN SEDENTARY SUBJECTS EXPOSED TO EITHER HEATED FLOOR OR HEATED CEILING.

François Grivel, Carinne Herrmann, Alain Hoefft and Victor Candas
L.P.P.E. - C.N.R.S./I.N.R.S
21, rue Becquerel, 67087 Strasbourg Cedex, France

INTRODUCTION

When investigating local thermal discomfort (reviews in 1, 2) attention has rarely be paid to local **skin** temperatures (3). We studied these local temperatures under two distinct but globally equivalent indoor climate patterns, namely heated floor (HF) **as** heated ceiling (**HC**). Both produced an overall thermal state of the **environment** corresponding to thermal balance fit to 0.6 clo-clothed **sedentary** ($M = 1.2$ met) subjects : 24.5°C operative temperature. Both conditions were **non** uniform due to vertical radiant temperature asymmetry which is an important criterion for admitted comfort limits (4). They **differed** in respect to the localisation of the source of radiant asymmetry : either below (HF) or above (HC) the subject. The aims of the investigation were : to collect simultaneously data **on** body (**skin**) temperatures and data **on** subjective thermal feelings (dependent variables) ; to examine the initial adjustments and the temporal evolution of the various (dependent) variables ; to compare the **results** in both climate patterns.

METHOD

Two non-uniform indoor conditions (heated floor : HF at 34°C , or heated ceiling HC at 45°C) were imposed in a climatic chamber to 2 groups of 10 lightly clothed male subjects (Ss), performing a computer task. When floor and ceiling temperatures (T) were increased beyond the comfort limits, compensation of air (T_a) and of the other wall (T_w) temperatures enabled the operative T (T_o) to be kept constant at 24.5°C . Ten local **skin** temperatures (T_{sl}) and various thermal judgments were collected throughout the **200-min** experimental test, which included an initial **30-min** stay at **uniform** $T_o = 24.5^{\circ}\text{C}$.

RESULTS

When non uniformity was generated, T_a and T_w were slightly decreased in both conditions and most of the T_{sl} **as** well **as** judgments of thermal sensations **also** decreased, although T_o was **theoretically** unchanged.

Results obtained after two hours of exposure showed that under HF, foot T increased steadily and leg T decreased **less**. Under HC, forehead, chest and shoulder T decreased less whereas lower back and inferior limb T showed a greater decrease. Mean **skin** temperature changes were -0.65°C and -1.10°C under HF and HC **respectively**.

In terms of thermal judgments, feet and floor were recognized as being **warm under HF** but corresponding local dissatisfaction was not expressed. In contrast to this, the shoulder, arm, back, hand **as** well **as** wall and air temperatures were estimated **as** being less and less warm (or cooler), inducing overall dissatisfaction (up to 6 Ss out of 10). Under HC, most parts of the body and of the room were judged **as** slightly cool, with **no** real change throughout the exposure : constant overall dissatisfaction was found in 4 Ss out of 10, in association with local dissatisfaction in foot, shoulder and hand.

CONCLUSION

It is concluded that the perception of the non-uniform indoor climate **in** our conditions was mainly influenced by those environmental components (here, floor and air) which exerted strongest influence on the thermal **sensors** ; the ceiling was uninfluential. Although operative T was supposed

to be kept constant, the **skin T** changes demonstrated that local and overall heat exchanges were different, depending on the heating source and on the thermal state of the remaining components.

REFERENCES

1. Mac Intyre, D.A., *Indoor Climate*.
Applied Science Publishers Ltd, London, 443 p. (pp.217-254) 1980.
2. Olesen, B.W., Local thermal discomfort.
Bruel & Kjaer Technical Review n° 1, 44 p, 1985.
3. Herrington, L.P. and Lorenzi, R.J., Effect of panel location on skin and clothing surface temperatures.
Heating Piping Air Conditioning, 21: 107-110, 1949.
4. ASHRAE Standard 55-1981, Thermal environmental conditions for human occupancy.
The American Society of Heating, Refrigerating and Air Conditioning Engineers Inc., 1791 Tullie Circle, NE, Atlanta, GA 30329, USA, 1981.